

# Performance Chart



Product: RESIDENTIAL SLIDING DOOR

Series: 370

Test Type:

Air infiltration (ASTM E 283)

Test Size:

\_\_\_\_\_  
\_\_\_\_\_  
199" X 96 1/2" (9/16 HS PVB )  
\_\_\_\_\_  
\_\_\_\_\_

Results:

0.3 CFM/F+ @ 6.24 PSF  
  
10.8 PSF  
  
POSITIVE 72 PSF      NEGATIVE 72 PSF

Water Resistance (ASTME 547/E 331)

\_\_\_\_\_  
\_\_\_\_\_

Uniform Static Loadtest (Design Load)  
(ASTM-E 330)

\_\_\_\_\_  
\_\_\_\_\_

Cyclic Design Load Test after Missile Impact  
in Accordance to Miami - Dade County  
(TAS 201 & 203)

199" X 96 1/2" (9/16 HS PVB )  
\_\_\_\_\_  
\_\_\_\_\_

POSITIVE 72 PSF      NEGATIVE 72 PSF

Forced Entry test AAMA 1302.5-1976  
Paragraph 3.1.1 Test A-3.15 Test G

\_\_\_\_\_  
\_\_\_\_\_

PASSED

Operating Force Opening

\_\_\_\_\_

13 POUNDS

Operating Force Closing

\_\_\_\_\_

14 POUNDS